



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

Courtyard School  
1270 Southeast Avenue  
Vineland, NJ 08360  
856-692-0414

www.sjwatertest.com  
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent Blank Date Sampled: 01/28/23 Time Sampled: 14:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126367					
Lead	2-FEB-2023 13:34	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:40	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Room 1 Date Sampled: 01/28/23 Time Sampled: 14:56

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126368					
Lead	2-FEB-2023 13:40	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:39	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Room 2 Date Sampled: 01/28/23 Time Sampled: 14:57

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126369					
Lead	2-FEB-2023 13:47	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:40	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Room 3 Date Sampled: 01/28/23 Time Sampled: 14:58

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126370					
Lead	2-FEB-2023 13:53	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:41	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Kitchen Date Sampled: 01/28/23 Time Sampled: 14:59

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126371					
Lead	2-FEB-2023 14:13	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:41	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Room 4 Date Sampled: 01/28/23 Time Sampled: 15:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126372					
Lead	2-FEB-2023 14:20	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:41	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

02/02/2023

Date



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

Courtyard School  
1270 Southeast Avenue  
Vineland, NJ 08360  
856-692-0414

www.sjwatertest.com  
NJ DEP Certified Lab # 08006

Sample Location: Room 5

Date Sampled: 01/28/23

Time Sampled: 15:02

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126373					
Lead	2-FEB-2023 14:26	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:43	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Room 6

Date Sampled: 01/28/23

Time Sampled: 15:03

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	V126374					
Lead	2-FEB-2023 14:33	<2.00	ug/L	2.0	15.5	SM3113B
Copper	2-FEB-2023 12:43	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

02/02/2023

Date